



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

Trade Name:	Noah® 5112
Chemical Identification:	dodecafluoro-2-methylpentan-3-one, $\text{CF}_3\text{CF}_2\text{C}(\text{O})\text{CF}(\text{CF}_3)_2$
Designation:	FK-5-1-12
Minimum Extinguishing Concentrations:	Class A – 3.35%
	Class B – 4.5%

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Extinguishing Agents

Zhejiang Noah Fluorochemical Co., Ltd
No. 6 Weft Nine Road
Shangyu Economic and Technological Development Zone
Shangyu, Zhejiang Province
China

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):

<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i>	
5600	August 2021

FM Approvals Listing Class: 5613

Project Identification: PR452412
Subsequent Revisions: PR461088

Approval Granted: 19 April 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

James E. Marquedant
VP, Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

2 December 2022

Date



Member of the FM Global Group